

TEXAS DEPARTMENT OF INSURANCE

Engineering Services Program / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104
Phone No. (512) 322-2212 Fax No. (512) 463-6693

PRODUCT EVALUATION DR-608

Effective Date: March 1, 2013
Reevaluation Date: **May 2017**

The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**.

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

6'-8" and 8'-0" Glazed Fiberglass Doors, Inswing & Outswing, Singles with Sidelites and Doubles, and 8'-0" Opaque Fiberglass Doors, Non-impact Resistant, manufactured by

Endura Products, Inc.
8811 West Market Street
Colfax, NC 27235
Telephone: (336) 668-2472

General Description:

System	Description	Label Rating	Drawing Number
1	6'-0" x 6'-8" Therma-Tru Glazed Fiberglass Double Door, Inswing/Outswing; (XX)	<u>Fiber Classic Door Panel</u> Inswing +35/-35 psf Outswing +40/-40 psf <u>Smooth Star Door Panel</u> Inswing +35/-35 psf Outswing +45/-45 psf	TX-4216
2	6'-0" x 8'-0" Therma-Tru Glazed Fiberglass Double Door, Inswing/Outswing; (XX)	<u>Fiber Classic Door Panel</u> Inswing +40/-40 psf Outswing +30/-30 psf <u>Smooth Star Door Panel</u> Inswing +35/-35 psf Outswing +25/-25 psf	TX-4217
3	3'0" x 6'-8" Therma-Tru Glazed Fiberglass Single Door w/ Sidelites & Integral Mullion, Inswing/Outswing; (OXO)	<u>Fiber Classic Door Panel</u> Inswing +45/-45 psf Outswing +40/-40 psf <u>Smooth Star Door Panel</u> Inswing +30/-30 psf Outswing +40/-40 psf	TX-4218

General Description (continued):

System	Description	Label Rating	Drawing Number
4	3'0" x 8'-0" Therma-Tru Glazed Fiberglass Single Door w/ Sidelites & Integral Mullion, Inswing/Outswing; (OXO)	<u>Fiber Classic Door Panel</u> Inswing +30/-30 psf Outswing +50/-50 psf <u>Smooth Star Door Panel</u> Inswing +30/-30 psf Outswing +35/-35 psf	TX-4219
5	3'6" x 8'-0" Therma-Tru Opaque Fiberglass Single Door, Inswing; (X)	<u>Classic Craft Rustic Door Panel</u> Inswing +45/-45 psf	TX-4222

Component Dimensions:

System	Overall Size	Panel Size	Maximum Daylight Opening Size
1	Inswing: 74 $\frac{1}{16}$ " x 81 $\frac{3}{4}$ " Outswing: 74 $\frac{1}{16}$ " x 80 $\frac{15}{16}$ "	35 $\frac{13}{16}$ " x 79 $\frac{1}{16}$ "	26" x 63 $\frac{5}{16}$ "
2	Inswing: 74 $\frac{1}{16}$ " x 97.78" Outswing: 74 $\frac{1}{16}$ " x 96.97"	35 $\frac{13}{16}$ " x 95 $\frac{1}{16}$ "	23 $\frac{3}{4}$ " x 78 $\frac{3}{4}$ "
3	Inswing: 112 $\frac{3}{8}$ " x 81 $\frac{3}{4}$ " Outswing: 112 $\frac{3}{8}$ " x 80 $\frac{15}{16}$ "	Panel: 35 $\frac{13}{16}$ " x 79 $\frac{1}{16}$ " Sidelite: 35 $\frac{13}{16}$ " x 79 $\frac{1}{16}$ "	26" x 63 $\frac{5}{16}$ "
4	Inswing: 112 $\frac{3}{8}$ " x 97.78" Outswing: 112 $\frac{3}{8}$ " x 96.97"	Door: 35 $\frac{13}{16}$ " x 95 $\frac{1}{16}$ " Sidelite: 35 $\frac{13}{16}$ " x 95 $\frac{1}{16}$ "	23 $\frac{3}{4}$ " x 78 $\frac{3}{4}$ "
5	Inswing: 43.44" x 82"	Door: 41 $\frac{3}{4}$ " x 95 $\frac{1}{16}$ "	NA

Components and Hardware:

System	Component	Quantity	Attachment Method
1-5	4" Butt Hinges	3 (6'-8" doors) 4 (8'-0" doors)	Hardware shall be installed in accordance with Endura drawings TX-4216, TX-4217, TX-4218, TX-4219 and TX-4222, dated September 6, 2012, signed and sealed by Lyndon F. Schmidt, P.E. on September 10, 2012.
	Lock and deadbolt strike plate	1 per lockset and deadbolt	
	Multi-point Lockset: Hoppe HLS 9000	1	

Product Identification (Certification Agency Label on Door):

System		
1-5	Certification Agency	Self-labeled by manufacturer
	Manufacturer's Name or Code Name	Endura Products, Inc.
	Product Name	Glazed Fiberglass Doors
	Test Standards	ASTM E330-02
	Drawing Number	TX-4216, TX-4217, TX-4218, TX-4219 or TX-4222

Impact Resistance:

Impact Resistant	Requirement
No	Impact protective system required when product is installed in areas where windborne debris protection is required

Installation:

System			
1-5	Type of Installation	Door Frame	
	Wall Framing	Spruce-Pine-Fir	
	Fastener Embedment	Minimum of 1 ½ inches into the wall framing	
	Fastener Location/Spacing	Head	The doors shall be installed and anchored in accordance with Endura drawings TX-4216, TX-4217, TX-4218, TX-4219 and TX-4222, dated September 6, 2012, signed and sealed by Lyndon F. Schmidt, P.E. on September 10, 2012.
		Sill	
		Side Jamb	
		Sidelites	
		Hinges	

Note: The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.